



December 6, 2002

Stan Gittelman
President
Humidity Control Systems, Inc.
56 Laxalt Drive
Moundhouse, NV 89706

Dear Stan:

This memo is to provide you with information on the testing that was performed on the walk-in box at the Washoe County Detention Facility at 911 Parr Blvd, in Reno, Nevada. The amperage on the compressor motor that serves the walk-in box was monitored for a period before and after the installation of the CoolerKing filters in the box.

The testing was performed between August and October of this year. The amperage measurement made showed a 10% reduction in compressor run time, which corresponds to a 10% reduction in the kWh usage of the compressor.

Additionally, prior to the installation of the filters there was standing water on the floor in this walk-in box. This water was gone approximately two weeks after installation of the filters, which is a good indication of a reduction in moisture content in the box. Additionally, there was less odor in the box, indicating a reduced amount of food spoilage that had occurred in the box.

These are our findings on this test and we look forward to performing another test to further understand the benefits of your product.

If you have any questions or need any other information, please call me at (775) 834-6893.

Sincerely,

A handwritten signature in dark ink, appearing to read 'Dave Wyllie', is written over a horizontal line.

Dave Wyllie, P.E.
Solution Development Director